

## City of Las Vegas Code and Interpretation

**AMEND:** 26

**DATE:** December 19, 2008

**CODE:**      2006 IBC ☐      2005 NEC ☐      Local Amendments ☐  
                 2006 IRC ☐      2006 UMC ☒      POOL CODE ☐  
                 2006 IECC ☐      2006 UPC ☐      MISC. ☐ Admin Code

**CODE SECTION:** Chapter 2 Definitions

**TOPIC:** What is the building department's interpretation of the definition of conditioned space? Per the UMC a conditioned space is a room or space normally occupied.

**PURPOSE/REASON:** If the area between two floors and in an attic space on the top floor that is used as a return air plenum and is considered conditioned space would the supply ducts in the return air plenum be required to be insulated per IECC and UMC.

**INTERPRETATION:** Any space within the envelope of an area that is heated or cooled is considered conditioned space. Any ducts within that space would not need to be insulated.

Approved: Chris Knight, CBO